

HE302

HEALTH ACT 1911

HEALTH (PUBLIC BUILDINGS) AMENDMENT REGULATIONS 1994

Made by His Excellency the Governor in Executive Council.

Citation

1. These regulations may be cited as the *Health (Public Buildings) Amendment Regulations 1994*.

Regulation 17 amended

2. Regulation 17 of the *Health (Public Buildings) Regulations 1992** is amended by repealing subregulation (4) and substituting the following subregulations —

“

(4) Where the ventilation of an occupied space in a public building is provided by an air conditioning system, the system shall be designed and installed so as to —

- (a) maintain the dry bulb temperature of air in the occupied space —
 - (i) if a function of the system is to cool air, at not more than 27° Celsius; and
 - (ii) if a function of the system is to heat air, at not less than 19° Celsius;
- (b) maintain the dew point temperature of air in the occupied space at not more than 17° Celsius; and
- (c) distribute air evenly throughout the occupied space at any speed not exceeding 0.25 metres per second.

(5) In this regulation —

- (a) a reference to an air conditioning system is a reference to equipment —
 - (i) for the purpose of controlling; or
 - (ii) for purposes including the control of,
the temperature of air in an occupied space, but is not a reference to evaporative cooling equipment; and
- (b) a reference to an occupied space in a public building is a reference to any area usually occupied by people when the building is in use that is between a floor, 180cm above the floor, 60cm from walls adjacent to the floor and 60cm from fixed equipment that is, or forms part of, an air conditioning system.

”

[* *Published in Gazette of 1 April 1992 at p. 1427-58.*]

By His Excellency's Command,

M. C. WAUCHOPE, Clerk of the Council.