

WA302

## WATER AUTHORITY ACT 1984

METROPOLITAN WATER SUPPLY, SEWERAGE AND DRAINAGE  
AMENDMENT BY-LAWS (NO. 2) 1993

Made by the Water Authority of Western Australia with the approval of the Minister for Water Resources.

**Citation**

1. These by-laws may be cited as the *Metropolitan Water Supply, Sewerage and Drainage Amendment By-laws (No. 2) 1993*.

**Principal by-laws**

2. In these by-laws the *Metropolitan Water Supply, Sewerage and Drainage By-laws 1981\** are referred to as the principal by-laws.

[\* Reprinted in the Gazette of 11 December 1986 at pp. 4557-800.  
For amendments to 25 March 1993 see 1991 Index to Legislation of Western Australia, pp. 531-2 and Gazettes of 3 January, 26 June and 31 December 1992.]

**Heading to by-law 10.0 amended**

3. The heading to by-law 10.0 of the principal by-laws is amended by deleting "(Implementation of Part 10 requires special Board approval)".

**By-laws 10.1 to 10.11 repealed and new by-laws substituted**

4. By-laws 10.1, 10.2, 10.3, 10.4, 10.5, 10.6, 10.7, 10.8, 10.9, 10.10 and 10.11 of the principal by-laws are repealed and the following by-laws are substituted —

## " 10.1 INTERPRETATION

10.1.1 In this by-law and in by-law 10.2 "AS 3500.1 — 1992" means the publication entitled "AS 3500.1 — 1992, National Plumbing and Drainage Code, Part 1: Water supply" published by the Standards Association of Australia.

10.1.2 Notwithstanding anything in AS 3500.1 — 1992, for the purposes of by-law 10.2 —

- (a) a reference in Section 4 of AS 3500.1 — 1992 to —
  - (i) "regulatory authority" shall be taken to be a reference to the Authority; and
  - (ii) "water service" or "water supply system" shall be taken to be a reference to a water supply system within the meaning of these by-laws;
- (b) Clause 4.2.3 of AS 3500.1 — 1992 shall be read as if "authorized by the regulatory authority" had been deleted;
- (c) Clause 4.5 of AS 3500.1 — 1992 shall be read as if "and be subject to the approval of the relevant regulatory authority" had been deleted; and
- (d) a reference in Section 7 of AS 3500.1 — 1992 to —
  - (i) a "Type B irrigation system" shall be taken to be a reference to an irrigation system described in Clause 7.2 (b) of AS 3500.1 — 1992 that is subject to, or is likely to be subject to, flooding or ponding;

- (ii) a "Type C irrigation system" shall be taken to be a reference to an irrigation system described in Clause 7.2 (c) of AS 3500.1 — 1992 that is subject to, or is likely to be subject to, flooding or ponding.

#### 10.2 ADOPTION OF PROVISIONS OF AS 3500.1 — 1992

For the purposes of cross connection control and backflow prevention —

- (a) a water supply system shall be designed, installed and maintained in accordance with the requirements of Section 4 (other than Clause 4.2.5) of AS 3500.1 — 1992;
- (b) an irrigation system shall be categorized, installed and maintained in accordance with the requirements of Section 7 of AS 3500.1 — 1992; and
- (c) an alternative water supply shall not be connected to a water supply system unless an appropriate backflow prevention device is fitted in accordance with the requirements of Clause 4.5 of AS 3500.1 — 1992. ”.

By resolution of the Board.

The Seal of the Water Authority of Western Australia was affixed hereto in the presence of—

K. C. WEBSTER, Chairman.  
W. J. COX, Managing Director.

Approved by the Minister for Water Resources.

P. D. OMODEI.