



# Government Gazette

OF

## WESTERN AUSTRALIA

(Published by Authority at 3.30 p.m.)

(REGISTERED AT THE GENERAL POST OFFICE, PERTH. FOR TRANSMISSION BY POST AS A NEWSPAPER.)

No. 71.]

PERTH : TUESDAY, 15th SEPTEMBER

[1959.

## HEALTH ACT, 1911-1957.

Department of Public Health,  
Perth, 3rd September, 1959.

HIS Excellency the Governor in Executive Council, acting under the provisions of the Health Act, 1911-1957, has been pleased to make the regulations set out in the Schedule hereunder.

LINLEY HENZELL,  
Commissioner of Public Health.

## Schedule.

## Regulations.

1. These regulations may be cited as the Sewerage and Drainage Fixtures and Fittings Regulations, 1959.
2. These regulations apply and have effect in the districts specified in Schedule "B" of these regulations.
3. No person shall install or use in the construction of any water closet that is or is to be connected to an apparatus for the bacteriolytic treatment of sewage a closet pan or flushing cistern unless the pan or cistern—
  - (a) is of a type in respect of which a certificate of registration has been issued by the Commissioner under these regulations; and
  - (b) (i) has been tested and branded as fit for use in accordance with the regulations; or
  - (ii) has been tested and branded as fit for use in accordance with the Metropolitan Water Supply, Sewerage and Drainage Act, 1909, and the by-laws made thereunder.
4. (1) No type of closet pan shall be considered by the Commissioner for registration unless—
  - (a) each pan is constructed of suitable non-absorbent materials and is of good workmanship and free from defects;
  - (b) each pan, when flushed, is completely washed over the interior surface;
  - (c) the water seal retained in each pan after each flushing is not less than one inch;